

5 Wheatfield Road
 Dunning Business Park
 Kirkcaldy
 KY1 3BH
 T: 01592 655591
 E: helpdesk@caledoniafs.com



MAINTENANCE REPORT

CALEDONIA

FIRE AND SECURITY

Site Name:	Charlestown Village Hall Queens Hall, Hall Row Charlestown DUNFERMLINE KY11 3EG
Customer Ref:	99-106-02
Contact Name:	Carol Hughes

Site ID:	CHARL003
Customer:	Charleston Village Hall
Invoice Address:	Per/ Carol Hughes 5 Orchard Square KY11 3JF

System Type:	Fire Fighting Equipment	Call Type:	Preventative Maintenance	Call No:	449112
---------------------	-------------------------	-------------------	--------------------------	-----------------	--------

Description/Notes:	Preventative Maintenance : Fire Extinguishers Notes : Please call Carol Hughes on mobile 30 mins before attending 07941 077528
---------------------------	--

Started:	19/02/25 @ 14:06:00
-----------------	---------------------

Finished:	19/02/25 @ 14:34:00
------------------	---------------------

Travel Time:	00:14:00
---------------------	----------

Remarks/Recommendations:	No additional work required
---------------------------------	-----------------------------

Inspection Summary				
Equipment Type	Qty Inspected	Recharge Qty	CAR Qty	Condemned
Water	1	1	0	0
Foam	3	0	0	0
Co2	1	0	0	0
Dry Powder	0	0	0	0
Wet Chemical	0	0	0	0
Hose Reel	0		0	0
Fire Blanket	1			0
Other	0	0	0	0

Part Number	Qty	Description
00001	1	Service charge
00003	6	Units inspected
03243	6	Sealing strip
03302	1	Co2 horn seal
03304	4	Discharge hose seal
00011	4	Stored pressure extinguisher gauge test
00008	1	Test extinguisher by discharge
21002	1	9 Litre Water Gas Extinguisher Refill
03301	1	Head cap sealing washer
21070	1	Re-pressurise extinguisher

With the exception of non-conforming equipment as noted above, all hand-held fire fighting equipment has been maintained in accordance with BS5306-3.

Technician (print)	Niall McManus
Technician (signature)	

Customer (print)	Carol Hughes
Customer (signature)	